

**SKS TOWER**  
**7 VIP ROAD, MOHAKHALI, DHAKA-1206**

**RE-TENDER NOTICE FOR WATER TREATMENT CHEMICAL**

1. Sealed tenders are hereby invited from genuine manufacturer/ suppliers for supplying 4 (four) categories of WATER TREATMENT CHEMICAL for 01 (one) year on 4050 TR Central Air-conditioning System of SKST. Chemicals must be manufactured in USA/Australia/Singapore/Malaysia. Tender schedule will be available at SKS TOWER office, Level-9, Mohakhali, Dhaka-1206 during office hours on cash payment of Tk.1,000/- (One thousand ) only (non-refundable) up to 12 August 2025. Tender to be dropped in the tender box kept in the office of the undersigned by 14 August 2025 up to 1130 hrs and it will be opened on the same day at 1200 hrs in presence of bidders (if any).
2. The authority reserves all the rights to accept or reject any item or full tender without assigning any reason whatsoever. Feel free to contact mobile number 01769056590 if any query.

Head of Project

Sl No	Short Description of Chemical	Requirement	Brand & Code Names	Quantity (Drum)	Capacity/ Drum (kg)	Rate/Kg	Total Amount
1,	Chemical to be used for corrosion control of ferrous, non-ferrous metal in closed system cooling water circuit. The chemical must be alkaline nature and control PH without dosing additional chemical. It must contain biologically treated ingredients. It must protect complete corrosion in the copper tube. <b><u>CHARACTERISTIC:</u></b> Specific Gravity : 1.16 to 1.50 Flammability : Non flammable PH as supplied : < 2.5 to 3.0	720 Kg					
2.	Chemical to be used for corrosion control of ferrous, non-ferrous metal in open cooling water circuit. The chemical must be alkaline nature and control PH without dosing additional chemical. It must contain biologically treated ingredients. It must protect complete corrosion in the copper tube. <b><u>CHARACTERISTIC:</u></b> Specific Gravity : 1.16 to 1.50 Flammability : Non flammable PH as supplied : < 2.5 to 3.0	1290 Kg					
3.	Non oxidizing Microbiocide Chemicals. <b><u>CHARACTERISTIC</u></b> Specific Gravity at 25 degree centigrade : 1.0 to 1.05 Flammability : Non flammable PH as supplied : > 6.5	450 Kg					
4.	Oxidizing Microbiocide Chemicals <b><u>CHARACTERISTIC</u></b> Specific Gravity at 25 degree centigrade : 1.02 to 1.05 Flammability : Non flammable PH as supplied : 4.2- 10.5	450 Kg					

## **TERMS AND CONDITIONS FOR SUPPLYING CHEMICALS**

1. The chemical to be used for central air conditioning system in cooling tower, chilled water line and condenser water line.
2. The supplier would submit lab test report from BUET in support of their respective chemicals, technical literature and ½ kg of sample (each category separately) along with the offer at their own expense.
3. Tk. 5% of quoted amount to be deposited in the form of bank draft/pay order along with the offer as earnest money in favor of SKS TOWER, Which will be returned after supplying the chemicals.
4. Tk.10% to be deducted from the final bill as security deposit and will be kept for 06 (six) months.
5. Duration of delivery: The chemicals to be delivered within 30 (thirty) days at site from the date of issuing of work order.
6. Tenderer may visit the site physically for further clarification if required.
7. Payment to be made after receiving the chemicals correctly as desired by SKST.
8. Previously supplied documents of chemicals for last 03 (three) years are to be submitted along with offer.
9. Chemicals must be manufactured in USA /Australia/ Singapore/Malaysia.
10. A certificate from the PRINCIPLE for genuinity of offered chemicals is to be given to this office along with offer.
11. A certified copy of agency ship/Dealership certificate must be submitted along with offer.
12. A copy of work order bearing minimum value of 3 (three) lacs should be submitted along with offer.
13. Original copy of MSDS (Material safety data sheet) and other related data sheet for supplying chemicals is to be given to this office along with offer.
14. CPP (Confidential product profile) for supplying chemicals must be submitted to this office along with offer.
15. If any excess chemical is required during 01 (One) year for controlling scale, corrosion and biological growth than the required quantity of chemicals are to be supplied at your own expense within this tendered amount as desired by SKST.
16. Attested copies of trade license, income tax certificate etc shall be submitted along with offer.
17. In three month's interval a test report of water has to be submitted to this office at your own expense.

**TO BE FILLED UP BY THE BIDDER**

1. Brand name of chemicals:

2. Code no. Of brand if any:

a) ..... to be used for .....

b) ..... to be used for .....

c) ..... to be used for .....

d) ..... to be used for .....

3. Country of origin.

4. Name of firms, where the above chemicals were supplied previously.

<u>Name of firms</u>	<u>Name of chemicals</u>	<u>Qty</u>	<u>Appearance</u>	<u>Date of supply</u>
----------------------	--------------------------	------------	-------------------	-----------------------

5. Any other information by the bidder, in support of quality of chemical.

Dated:

Signature :

Name :

Designation :

Address/Firm:

Phone :